



## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 07/07/2025

It is certified that an inspection team headed by Dr. M. P. Awhire

(Name of Officers with designation) from Medical Officer Primary Health Centre

inspected the Anant Nirmal Global High School Nasarapur

(Name & Address of the school) on 07/07/25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 1) Chemical Analysis of Drinking water

of 44/2025 15.26/6/2025 (PHED Lab) dated 7.9/7.6.2025 certified that

the ANGHS, Raghunath Dnyanpeeth (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 1 year

Regularly checks

Drinking water For

Biological & chemical Analysis

To Anant Nirmal Global

School Dhangwad

(Name & Address of the Institution)

Signature with Seal: Dr. M. P. Awhire

Name: Dr. M. P. Awhire

Designation: Medical Officer Grp A

Name & Address of the Office / Department: PHC Nasarapur, Bhori, Dist. Pune

Pin- 412 213

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



# भुजल सर्वेक्षण आणि विकास यंत्रणा

उपविभागीय प्रयोगशाळा, भोर

दूरध्वनी क्र.- ०२११३-२२२०२७

पाणी नमुन्याचा सूक्ष्मजीवीय अहवाल


प्रती,	:- अनंत निर्मल ग्लोबल स्कूल धांगवडी
पाठविणाऱ्याचे पत्र क्र.व दिनांक	:- ०४.०७.२०२४
प्रयोगशाळा संदर्भ क्रमांक	:- १४०५
नमुना घेतल्याचा दिनांक	:- ०४.०७.२०२४
नमुना पोहचल्याचा दिनांक	:- ०४.०७.२०२४
परीक्षण सुरू केल्याचा दिनांक	:- ०४.०७.२०२४

नमुन्याचे विवरण	परीक्षणाचे निष्कर्ष			इतर अभिप्राय
	प्रती १०० मि.ली. नमुन्यातील संभाव्य सूक्ष्मजंतूंची संख्या			
	कोलीफॉर्मस	थर्मोटोलरंट कोलीफॉर्मस	इ. कोलाय	
एकूण नमुने = १	-	-	-	सदरील पाणी नमुना पिण्यास योग्य आहेत.
पिण्यास योग्य नमुने = १	-	-	-	
पिण्यास अयोग्य नमुने = ०	-	-	-	

अभिप्राय:- पिण्यास अयोग्य पाण्यावर योग्य प्रमाणात क्लोरीनची प्रक्रिया केल्यानंतर व सूक्ष्मजीवीय पुनर्तपसणीनंतर पिण्यास योग्य असल्याची खात्री झाल्यानंतरच ते पाणी पिण्यासाठी वापरता येईल.


अहवाल क्रमांक: SDL/Bhor/ १२ / २०२४

दिनांक: ०८.०७-२०२४

  
Principal  
Rajgad Dnyanpeeth's  
Anant Nirmal Global School  
Dhangawadi, Pune-412206



  
Estate Manager  
Rajgad Dnyanpeeth Technical Campus  
Dhangawadi, Pune-412205.

  
अनुजैविक तज्ञ  
उपविभागीय प्रयोगशाळा, भोर





**DEPUTY DIRECTOR, HEALTH SERVICES**  
**STATE PUBLIC HEALTH LABORATORY, PUNE.**  
**Near St. Mary School And Church, Pune 411001**

Telephone - Office :- (020) 263300225 Ext. 223

Email : statehealthlab@gmail.com



HEALTH SERVICES

NO. SPHL PUNE /Desk -79 / 769 / 2025. DATE:- 25/06/2025

**Report on Chemical Analysis of Drinking Water**

Sent by :- Anant Nirmal Global School, Dhangavadi, Tal- Bhor, Dist - Pune.

With Ref. letter No :- ----

Dated :-13 /06/2025

Date of Collection :- ----

Date of Receipt :- 13 -06-2025

Date of Examination :-16 / 06 / 2025 onwards

(All the Analytical Results are in mg. / Lit. except pH, Turbidity)

SR. NO	TEST PARAMETER	S.No. - 1 ( P-526) Filter Water	BIS Specifications 10500 : 2012 Normal Values	
			Desirable limit	Permissible limit
1	Physical Appearance	Clear	---	---
2	Odour	agreeable	agreeable	agreeable
3	Turbidity ( as N.T.U. )	0.10	1.0	5.0
4	pH Value	6.66	6.5 to 8.5	No relaxation
5	Chlorides ( as Cl )	21.84	250	1000
6	Nitrates ( as No3 )	1.32	45	No relaxation
7	Total Hardness ( as Caco3 )	66.86	200	600
8	Alkalinity ( as Caco3 )	31.55	200	600
9	Total Dissolved Solids	99.2	500	2000
10	Iron ( as Fe )	ND	1.0	No relaxation
11	Fluoride ( as F )	ND	1.0	1.5

- ND :- Not detected.
- This report is restricted only for the sample /s submitted to this laboratory.
- It is presumed that the representative sample from the source is sent for analysis.
- This Sample /s is /are not collected by this laboratory.

**Remark :-** S.No. -1 is chemically fit for drinking purpose on the basis of analysed parameters Only. However, this water source can be used for drinking purpose only after proper treatment, disinfection & ascertaining its bacteriological quality frequently or regularly.

Forwarded With Compliments To :- Anant Nirmal Global School, Dhangavadi, Tal- Bhor, Dist - Pune.

Fees	600 /-
Receipt No.	7760395
Date	13/06/2025

Senior Scientific Officer  
State Public Health Laboratory  
Pune-411 001